



Department of Health

KATHY HOCHUL
Governor

MARY T. BASSETT, M.D., M.P.H.
Commissioner

KRISTIN M. PROUD
Acting Executive Deputy Commissioner

March 4, 2022

Mayor and Village Board
Village of Copenhagen
P.O. Box 237
Copenhagen, NY 13626

RE: Year 2022 Public Water System Monitoring Requirements

Dear Supplier of Water:

The Year 2022 monitoring requirements for your community water systems are **attached**. You are responsible for all testing and reporting of analytical results from an appropriate laboratory certified by New York State. **Do not collect samples until your operator has contacted the writer or Mr. Curley.**

Routine daily and monthly monitoring requirements remain unchanged.

You are responsible for preparing and distributing an updated Annual Water Quality Report (AWQR) **prior to May 31st**. Remember to include all sampling data in your AWQR tables that were detected parameters (If you monitor less than once per year for some parameters, you must include the most recent data.). Certification that the AWQR was delivered must be provided **by September 1st**.

This letter and attached sample schedule must be displayed at the water treatment plant and be available for review upon inspection.

If you have any questions, please contact the writer or Mr. Curley at (315) 785-2277.

Sincerely,



Michael J. Tracy, P.E.
Professional Engineer 1

Enc. 2022 Monitoring Requirements

cc: Brandon Cooney – District Director
Claude Curley, P.E. – District Engineer
Dave Patocki – Water Treatment Plant Operator

SDWIS/State Water Sample Schedule Report

COPENHAGEN VILLAGE PWS ID: NY2402361

Due 2022	Contaminant (Group)/ Sample Location/Frequency	Last Compliance Results	Sample Requirements
Coliform, Total (TCR)			
<input checked="" type="checkbox"/>	Location: Distribution System Frequency: 1 Sample Monthly Sample collection should be rotated amongst several representative sites within the distribution. Free chlorine residuals must be taken at the time of sampling.		1 Sample must be collected every month.
Nitrate			
<input checked="" type="checkbox"/>	Location: WOODBATTLE WTP ID: TP001 Frequency: 1 Sample Yearly Sample Point: WOODBATTLE ENTRY POINT Sample Point No.: EP001 Sample Point Type: EP-Entry Point Collect one nitrate sample at each entry point annually.	Samples last collected: 9/18/2021	Sample must be collected by 12/31/2022
<input checked="" type="checkbox"/>	Location: STODDARD WTP ID: TP002 Frequency: 1 Sample Yearly Sample Point: STODDARD WTP ENTRY POINT Sample Point No.: EP002 Sample Point Type: EP-Entry Point Collect one nitrate sample annually.	Samples last collected: 9/18/2021	Sample must be collected by 12/31/2022
Part 5-1.52 Table 12 - Radiological			
<input checked="" type="checkbox"/>	Location: WOODBATTLE WTP ID: TP001 Frequency: 1 Sample Yearly Sample Point: WOODBATTLE ENTRY POINT Sample Point No.: EP001 Sample Point Type: EP-Entry Point Collect one radiological sample for Gross Alpha, Radium 226, and Radium 228 at the entry point between July 1st and September 30th.	Samples last collected: 12/13/2021	Next sample must be collected between 7/1 and 9/30 within a single year by 9/30/2022
Part 5-1.52 Table 8B - Primary Inorganic Chemicals			
<input checked="" type="checkbox"/>	Location: STODDARD WTP ID: TP002 Frequency: 1 Sample Every 3 years Sample Point: STODDARD WTP ENTRY POINT Sample Point No.: EP002 Sample Point Type: EP-Entry Point Collect one Primary IOC sample at the entry point every three years.	Samples last collected: 11/18/2019	Sample must be collected by 12/31/2022
Part 5-1.52 Table 9A - Disinfection Byproducts/Stage 2			
<input checked="" type="checkbox"/>	Location: DISTRIBUTION SYSTEM ID: DS001 Frequency: 1 Sample Yearly Sample Point: 801 COMMUNITY BLDG Sample Point No.: LRAA1 Sample Point Type: DS-Distribution System Collect one DBP (TTHM and HAA5) sample annually, in the month of August at the sample point specified above.	Samples last collected: 9/8/2021	Next sample must be collected between 8/1 and 8/31 within a single year by 8/31/2022
Part 5-1.52 Table 9B - Principal Organic Chemicals			
<input checked="" type="checkbox"/>	Location: STODDARD WTP ID: TP002 Frequency: 1 Sample Every 3 years Sample Point: STODDARD WTP ENTRY POINT Sample Point No.: EP002 Sample Point Type: EP-Entry Point Collect one POC sample for every three years.	Samples last collected: 11/18/2019	Sample must be collected by 12/31/2022

SDWIS/State Water Sample Schedule Report

COPENHAGEN VILLAGE PWS ID: NY2402361

Due 2022	Contaminant (Group)/ Sample Location/Frequency	Last Compliance Results	Sample Requirements
----------	---	-------------------------	---------------------

Part 5-1.52 Table 9C - PFOA, PFOS and 1,4-Dioxane

- | | | | |
|-------------------------------------|---|--|--|
| <input checked="" type="checkbox"/> | Location: WOODBATTLE WTP ID: TP001
Frequency: 1 Sample Yearly
Sample Point: WOODBATTLE ENTRY POINT
Sample Point No.: EP001
Sample Point Type: EP-Entry Point

Please collect one sample representative of the entry point. | | Sample must be collected by 12/31/2022 |
| <input checked="" type="checkbox"/> | Location: STODDARD WTP ID: TP002
Frequency: 1 Sample Yearly
Sample Point: STODDARD WTP ENTRY POINT
Sample Point No.: EP002
Sample Point Type: EP-Entry Point

Please collect one sample representative of the entry point in the 3rd quarter to represent quarter missed in 2021 sampling effort. | | Next sample must be collected between 7/1 and 9/30 within a single year by 9/30/2022 |

Part 5-1.52 Table 9C - Synthetic Organic Chemicals

- | | | | |
|-------------------------------------|--|---------------------------------------|--|
| <input checked="" type="checkbox"/> | Location: STODDARD WTP ID: TP002
Frequency: 1 Sample Every 3 years
Sample Point: STODDARD WTP ENTRY POINT
Sample Point No.: EP002
Sample Point Type: EP-Entry Point

Collect one SOC sample for every three years. | Samples last collected:
11/18/2019 | Sample must be collected by 12/31/2022 |
|-------------------------------------|--|---------------------------------------|--|

Part 5-1.42 and 5-1.47 - Lead and Copper

- | | | | |
|--------------------------|---|---|--|
| <input type="checkbox"/> | Location: DISTRIBUTION SYSTEM ID: DS001
Frequency: 20 Samples Every 3 years
Sample Point: DISTRIBUTION VARIOUS
Sample Point No.: DS001
Sample Point Type: DS-Distribution System

All sample locations must be indicated in your lead and copper sampling plan. Signed homeowner certification forms must accompany the sample results. | 20 Samples Collected
on or Before: 9/11/2020 | Next 20 samples must be collected between 6/1 and 9/30 within a single year by 9/30/2023 |
|--------------------------|---|---|--|

Part 5-1.52 Table 12 - Radiological

- | | | | |
|--------------------------|---|--------------------------------------|---|
| <input type="checkbox"/> | Location: STODDARD WTP ID: TP002
Frequency: 1 Sample Every 9 years
Sample Point: STODDARD WTP ENTRY POINT
Sample Point No.: EP002
Sample Point Type: EP-Entry Point

Collect one radiological sample for Gross Alpha, Radium 226, and Radium 228 every nine years at the entry point. | Samples last collected:
11/2/2017 | Next sample must be collected by 12/31/2026 |
|--------------------------|---|--------------------------------------|---|

Part 5-1.52 Table 8B - Primary Inorganic Chemicals

- | | | | |
|--------------------------|--|---------------------------------------|---|
| <input type="checkbox"/> | Location: WOODBATTLE WTP ID: TP001
Frequency: 1 Sample Every 3 years
Sample Point: WOODBATTLE ENTRY POINT
Sample Point No.: EP001
Sample Point Type: EP-Entry Point

Collect one IOC sample at each entry point. | Samples last collected:
10/21/2020 | Next sample must be collected by 12/31/2023 |
|--------------------------|--|---------------------------------------|---|

Part 5-1.52 Table 9B - Principal Organic Chemicals

- | | | | |
|--------------------------|---|---------------------------------------|---|
| <input type="checkbox"/> | Location: WOODBATTLE WTP ID: TP001
Frequency: 1 Sample Every 3 years
Sample Point: WOODBATTLE ENTRY POINT
Sample Point No.: EP001
Sample Point Type: EP-Entry Point | Samples last collected:
10/21/2020 | Next sample must be collected by 12/31/2023 |
|--------------------------|---|---------------------------------------|---|

SDWIS/State Water Sample Schedule Report

COPENHAGEN VILLAGE PWS ID: NY2402361

Due Contaminant (Group)/

2022 Sample Location/Frequency

Last Compliance Results

Sample Requirements

Collect one POC sample at the Entry Point.

Part 5-1.52 Table 9C - Synthetic Organic Chemicals



Location: WOODBATTLE WTP ID: TP001

Frequency: 1 Sample Every 3 years

Sample Point: WOODBATTLE ENTRY POINT

Sample Point No.: EP001

Sample Point Type: EP-Entry Point

Collect one SOC sample at each entry point every 3 years.

Samples last collected:
10/21/2020

Next sample must be collected by 12/31/2023